

VOC Content Test Certificate

Wednesday 28th August 2019

Supplier: A & I Coatings Pty Ltd (7 Lackey Road, Moss Vale, NSW, 2577, Australia).

Sample Description: 2 pack E4110 A & E4110B

Date Tested: July 2019 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:

Specification Green Building Council of Australia Green Star Design & As Built V1.1 13.1.1 Green Star Interiors V1.1 12.1.1B	Enviroset 4110
Primers, sealers and prep coats: 65 grams per Litre	21 grams per Litre as VOC content per material
One and two pack performance coatings for floors: 140 grams per Litre	21 grams per Litre as VOC content per material
<p><i>We hereby certify that Enviroset 4110 is below the VOC Content limits of chosen categories specified by Green Star Design, Green Building Council of Australia</i></p>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Tuan Duong
BE (Chem. Eng.)
Consultant



Luke Morley
BSc (Tech)
Consultant

V1907044A